

Appendix D

**The Power Company Limited
Commerce Act (Electricity Distribution Thresholds) Notice 2004 and Amendment Notice 2006
Quality Inputs and Calculations for the
Assessment Date 31 March 2007**

Year	SAIDI (Interruption Duration)			SAIFI (Interruption Frequency)		
	Class B	Class C	Total	Class B	Class C	Total
1999	60.90	276.50	337.40	0.55	5.49	6.04
2000	73.90	339.60	413.50	0.56	5.89	6.45
2001	16.00	130.00	146.00	0.13	2.76	2.89
2002	20.00	117.80	137.80	0.14	2.73	2.87
2003	18.90	147.80	166.70	0.11	3.22	3.33
Five Year Average	37.94	202.34	240.28	0.30	4.02	4.32
2004	11.10	140.70	151.80	0.10	3.42	3.52
2005	7.72	117.68	125.40	0.04	2.96	3.00
2006	14.77	143.56	158.34	0.08	2.91	2.99
2007	42.44	135.11	177.56	0.23	2.80	3.02